

**MIAMI-DADE COUNTY FIRE RESCUE DEPARTMENT  
FIRE ENGINEERING & WATER SUPPLY SERVICES  
FIRE FLOW REPORT**

**DATE:** 06/18/2020      **LOCATION:** 17071 W Dixie Hwy  
**ID NUMBER:** X2020105323      **FEE:** 293.56

**STATIC PRESSURE:** 67 PSIG      **PITOT 1:** 13 (1) 2.5 IN. ....PSIG  
**RESIDUAL PRESSURE:** 37 PSIG      **PITOT 2:** 13 (2) 2.5 IN. ....PSIG  
**PITOT 3:** \_\_\_\_\_ (1) 4.5 IN. ....PSIG

**HYDRANT FLOW:** 1074.4542800882688093  
**AVAILABLE FLOW @ 20 PSIG:** 1369

**TIME OF TEST:** \_\_\_\_\_  
**TEST BY:** Cameron  
**STATION:** \_\_\_\_\_  
**PURPOSE:** \_\_\_\_\_

**SPRINKLER STATIC:** 62  
**SPRINKLER RESIDUAL:** 32  
**SPRINKLER FLOW:** 999

**COMMENTS:**

Melissa Ross  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

  
\_\_\_\_\_  
O.T.C SIGNATURE